



1.0 GENERAL

1.1 Summary

- A. All Rolling Fire Doors shall be as manufactured by Service Door Industries, Mississauga, Ontario, Canada. Furnished materials shall include all curtains, bottom bars, guides, brackets, hoods, operating mechanisms and any special features.
- B. Work not to be included by SDI includes design of, material for and preparation of door openings but not limited to structural or miscellaneous iron work, access panels, finish painting, electrical wiring, conduit and disconnect switches.

1.2 Quality Assurance

- A. All rolling fire doors shall be constructed in accordance with Warnock-Hersey testing agency requirements and shall bear a [4 hour][3 hour][1-1/2 hour] [3 and 4 hour] rating label.

2.0 PRODUCTS

2.1 Materials

- A. The door curtain shall be constructed of interconnected strip steel slats conforming to ASTM A-653. The curtain slat shall be a (2-1/4" high by 3/4" deep) curved slat as designated by SDI.
- B. The finish on the door curtain shall be:
 - 1. Hot dipped galvanized G-90 coating consistent with ASTM A-653
- C. The bottom bar shall consist of two 1/8" steel angles mechanically joined together. The finish on the bottom bar shall be one (1) coat of prime paint.
- D. The guides shall consist of 3 steel angles bolted together with 3/8" fasteners to form a channel for the curtain to travel. The wall angle portion shall be continuous and fastened to the surrounding structure with minimum 1/2" fasteners. The finish on the guide angles shall be one (1) coat of prime paint.
- E. The brackets shall be constructed of steel not less than 1/4" thick and shall be bolted to the wall angle with minimum 1/2" fasteners. The finish on the brackets shall be one (1) coat of prime paint.
- F. The barrel shall be steel tubing of not less than 4" in diameter. Oil tempered torsion springs shall be capable of correctly counter balancing the weight of the curtain and shall have both a main and an auxiliary spring. The barrel shall be designed to limit the maximum deflection to .03" per foot of opening width. The springs shall be adjusted by means of an exterior wheel. The finish on the barrel shall be one (1) coat of prime paint.

- G. The hood shall be fabricated from 24 gauge galvanized steel and shall be formed to fit the curvature of the brackets. The finish on the hood shall be galvanized finish.

2.2 Operation

- A. All FSF fire doors shall have an automatic closing device and Whisper Governor to control the downward speed of the door, which shall become operational upon the fusing of a 160 degree fusible link. The door shall have an average closing speed of not less than six (6) inches per second and not more than twenty-four (24) inches per second as indicated in NFPA Bulletin 80. The Whisper Governor shall be fail-safe, maintenance-free, fully enclosed and warranted for the lifetime of the door. Once the door has closed, it should be able to be reset by one person on one side of the door only.
- B. FSF operated doors **shall stay open at all times** unless released by fusible link or optional solenoid release device.

3.0 EXECUTION

3.1 Installation

- A. All SDI Rolling Fire Doors shall be installed in accordance with NFPA Bulletin 80 by an authorized SDI Distributor.

3.2 Warranty

- A. All SDI Rolling Fire Doors shall be warranted for a period of twelve (12) months from the time of shipment against defects in workmanship and materials.